

## DEPARTMENT OF ENVIRONMENTAL PROTECTION & SUSTAINABILITY

### Interoffice Memo

TO: Glen Keller  
Bureau of Engineering & Construction, Sanitary Sewer Design Section

FROM: Thomas L. Vidmar, P.E. /signed/  
Deputy Director, EPS

DATE: May 2, 2014

SUBJECT: ABBIE PLACE RELIEF SEWER  
Stormwater Management Variance  
Gwynns Falls Watershed  
**EPS Project ID: M130276**  
**Tracking Number: 04-14- 1806**

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations. This project is for the installation of 3440 linear feet of sewer pipe. The existing cover conditions will be re-established once the pipes are installed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Tony Okechukwu Ezirike, P.E. of my staff at 410-887-3768 should you have any questions.

TLV:jcm